



CE-CERTIFICATE

CENTEXBEL TYPE TESTING | CERTIFICATION REPORT N° jw3203_2025

According to reports N° 25.03575.01, 25.03575.02 and 25.03583.01 dated 29/08/2025, we confirm that the below mentioned item was tested at CENTEXBEL, Notified body #0493, with reference to EN 14041:2004+AC:2006 – Resilient, textile and laminate floor coverings - Essential characteristics. The item shows

EU fire classification: B_{fl}-s1
glued on a non-combustible substrate¹
Compliance with content of pentachlorophenol
Formaldehyde class: E1
Dynamic coefficient of friction: Dry slip resistance

¹End use substrates of classes A1 or A2-s1,d0 (ISO 13238:2010 § 5.2.2)

Provided that it is properly applied.

The evaluation of this properties is based on evaluation scheme specified in EN 14041:2004+AC:2006 – Resilient, textile and laminate floor coverings - Essential characteristics . These products come under the EU CPR 305/2011 directives for product safety. Products falls under system 3 of assessment and verification of constancy of performance like declared by the manufacturer.

Product type	PVC flooring
Product range	2.0-5.0 mm
Company	ZHANGJIAGANG KAILIDA PLASTIC CO., LTD.
	No. 107, Kaidi Road, Tianzhuang Village
	Gangkou, Fenghuang Town
	Zhangjiagang City, Jiangsu
	China

Certificate No. jw3203_2025 is valid until 28/08/2030
Centexbel | Technologiepark 7 | BE 9052 Gent | Belgium, 19/09/2025

Inge De Witte, PhD
Certification Manager